

**Village of Winneconne Treatment Facility Overflow Public Notice**

Notice is hereby given pursuant of s. NR 210.21 (5) that the Village of Winneconne Wastewater Treatment Facility (WWTF) experienced a Treatment Facility Overflow (TFO) event from 9:15 AM on March 26<sup>th</sup>, 2020 until 10:15 AM March 26<sup>th</sup>, 2020. The estimated gallons of the overflow were 1,000 gallons. The overflow occurred due to a plugged pipe at the Wastewater Treatment Facility (WWTF).

Plant staff cleared the blockage in the pipe which mitigated the impacts to public health, the environment, and property. The TFO event was reported to the Wisconsin Department of Natural Resources pursuant of NR 210.21 (4).